



SQB Solar Booster Pump

for Manual and Automatic operation

The SQB peripheral vane solar booster pump is equipped with a permanent magnet, brushless motor that allows for efficient energy usage. It features the latest solar pump technology for a sustainable water supply. These pumps are used for pressure boosting and water transfer of drinking water and small irrigation systems. Suitable for applications where there is no electricity or for cost saving in power consumption.

Product Feature:

- Permanent magnet, brushless motor, saving energy and offering maximum efficiency.
- NSK bearings with ceramic mechanical seal.
- Intelligent dry run protection.
- MPPT function offers higher utilization rate of solar energy.
- Water proof and leak proof due to double water seal.
- Soft start protection.
- Over/under current protection.
- Variable speed control

Max Flow: 2000L/h
Max Head: 30m
Discharge 25mm
Power` 250watt
Voltage DC24

Working Conditions:

Max pumped liquid temperature: 35°C
 PH capability: 6.5 - 8.5
 Max control box ambient temperature: 50°C

Operation Modes:

Manual:

- 1) Always On during daylight hours
- 2) Always On with connection of a regulator and series connected 12V deep cycle batteries.

Automatic:

Option 1 or 2 of manual operation with addition of pressure activated switch.

For more information see wiring diagram on page 5 & 6.


Technical Summary:

MODEL	DC MOTOR VOLTAGE (V)	MAX INPUT DC V.O.C (V)	MAX INPUT AMPERAGE	POWER (WATT)	MAX FLOW (m³/h)	MAX HEAD (m)	OUTLET (INCH)	CABLE SIZE
SQB250-30/2A	24	48	17	250	2	30	1"	3 Core 2.5mm²



SQB Solar Booster Pump

Performance Data:



Model	Flow	l/min	0	6.6	13.3	20	26.6	33.3
Model		l/hour	0	400	800	1200	1600	2000
SQB250-30/2A	HE	AD	30	28	25	20	12	0

Included in Kit:



Excluded in Kit: Require for Automatic operation

Regulator	2 x 12V Deep cycle Batteries	5 Way Connector	Pressure Tank	Pressure Switch	Pressure Gauge	Flexible Hose
	Service Bridge And Advances Ad	9 =				

www.tracerpumps.co.za TRACER PUMPS | CATALOGUE



Control Panel







Control Panel

Key	Function
Set	Factory setting. Do not use.
en ter	Factory setting. Do not use.
Up	RPM setting, to increase the RPM. In the Error State the key is used to turn the error display On or Off.
Down	RPM setting, to decrease RPM.
Switch	In operation status this key is used to display the different values: Voltage Speed Current Power
On/off	Power button - Switch unit On and Off manually.

Control Parameters:


Model	Pump Voltage	Max Input Current (A)	VOC (V)	Operating Voltage Range	Operating Temperature	
CN24	24V	17	48V	21 - 48	-15°C - 60°C	

www.tracerpumps.co.za TRACER PUMPS | CATALOGUE




Wiring Diagram

Manual Operation:



Automatic Operation:





Control Panel

Error Codes:

No	Code	Description	Cause	Solution	Recovery process
1	P0	Unit over-current	Incorrect motor voltage. UVW short circuit connection.	Replace with correct specification. Rewire according to diagram.	Automatically after 30sec.
2	P43	Phase protection	UVW open circuit.	Rewire according to diagram and ensure all wires are secured properly.	Automatically after 30sec.
3	P46	Stalling protection	Incorrect motor cable Length. Pump bearing stuck.	Replace with correct specification. Decrease length or replace with larger diameter cable. (See Cable chart) Return unit to supplier for evaluation and repair.	Automatically after 30sec.
4	P49	Software over-current	Pump bearing stuck. UVW short circuit connection.	Return unit to supplier for evaluation and repair. Rewire according to diagram and ensure all wires are secured properly.	Automatically after 30sec.
5	P50	Low voltage protection	Low input voltage.	Check panel wiring and ensure panels provide sufficient voltage according to pump specification.	Immediately
6	P51	High voltage protection	Input voltage too high.	Check panel wiring and ensure panel voltage specification meets pump requirement.	Immediately
7	P48	Dry-run protection	Water level below inlet of pump. Air trapped in pipework.	Lower the pump or wait until well refills. Switch unit off and wait for 30seconds.	Unit will automatically start after 30minutes.
8	P60	High temperature protection	High temperature protection.	e protection. Temperature of controller more than 90°C.	
9	E00-10	Current sampling failure		Switch power off and restart after 30 seconds.	Restart unit to clear error.
10	E-11	MOS drive voltage abnormal		Return unit to supplier for technical evaluation.	
11	E-12	Well Light illuminated	Water source is dry or at low level	Check water supply level and ensure it's above low level sensor, if below refill to acceptable level. If water level is above sensor level, check suction line for any obstructions.	Unit will automatically start after 30sec once supply has been restored.
12	E-13	Tank Light illuminated	Water level is above sensor. (Tank Full)	9,	
13	PL	Power shortage	PV Panel not receiving sufficient sunlight. PV Panels not wired correctly.	Unit will start up automatically as soon as sky clears. Check wiring and ensure that it is correct according to wiring diagram.	Unit will restart automatically after 30 seconds the first 5 times, there after it will restart after 30 minutes.
14	ALARM	Reverse wiring protection	Panel incorrectly wired	Check wiring and ensure that it is correct according to wiring diagram.	Restart unit to clear error.

DC Cable Chart: PV Panel to Control Box

Unit						Cable Le	ngth (m)					
Voltage	15	30	45	60	75	90	105	120	135	150	175	200
24V	4mm²	6mm²	10mm²	16mm²	16mm²	25mm²	25mm²	35mm²	35mm²	35mm²	50mm²	50mm²
48V	2.5mm²	4mm²	6mm²	10mm²	10mm²	16mm²	16mm²	25mm²	25mm²	25mm²	35mm²	35mm²
72V	2.5mm²	4mm²	6mm²	10mm²	10mm²	10mm²	10mm²	16mm²	16mm²	16mm²	25mm²	25mm²
96V	2.5mm²	2.5mm²	4mm²	4mm²	6mm²	6mm²	10mm²	10mm²	10mm²	10mm²	16mm²	16mm²
110V	2.5mm²	2.5mm²	4mm²	4mm²	6mm²	6mm²	10mm²	10mm²	10mm²	10mm²	16mm²	16mm²

AC Cable Chart: Control Box to Pump

				C	ABLE DIAMETE	R		
Watt		1.5 mm ²	2.5 mm ²	4 mm ²	6 mm ²	10 mm ²	16 mm²	25 mm ²
210	_		40	60				
300	LENGTH		110	170	260			
500			110	170	260			
750	CABLE		160	260	380			
1200	Ŭ		160	260	380			

www.tracerpumps.co.za TRACER PUMPS | CATALOGUE